

# Distributionally Robust Decentralized Scheduling between the Transmission Market and Local Energy Hubs

Shengfei Yin, *Member, IEEE*, and Jianhui Wang, *Fellow, IEEE*

**Abstract**—The cross impacts between transmission and distribution systems have drawn extensive attention, where multi-energy carriers become increasingly dominant in local market operations. Local energy hubs, integrated with multi-energy carriers, e.g., electricity, gas, heat, present great potentials to provide adequate power and reserve support for the transmission system, which could mitigate issues such as boundary mismatches in the upstream market. However, energy hubs are typically equipped with abundant distributed renewable resources. Such local uncertainties can adversely affect the well-being of the coordinated multi-energy market hierarchy. This paper presents a novel multi-period scheduling framework that considers the coordination between the transmission network and distribution energy hubs. Each agent performs local scheduling operations capturing independent uncertainties via a distributionally robust formulation. We then apply a tailored accelerated augmented Lagrangian algorithm embedded with the column-and-constraint method to decentralize the overall operation with agents' privacy preserved. The fast and convergent feature of the algorithm ensures its scalability and reliability in real-world applications of the energy hub design with transmission coordination. Numerical experiments confirm the efficacy of the proposed method.

**Index Terms**—Transmission and distribution coordination, multi-energy carrier, distributionally robust optimization, decentralization, augmented Lagrangian.

## NOMENCLATURE

### 1) Sets:

$\mathcal{T} / \mathcal{D}$	Transmission/distribution system components
$S / N$	Sending/receiving bus of T&D lines
$A$	Bus mapping of installed units

### 2) Indices:

$g / r / f$	Conventional unit/renewable unit/line
$a / ag / af$	Gas retail/gas unit/gas pipeline
$t / tg / tf$	Heat source/CHP/heat pipeline
$l / al / tl$	Electric/gas/heat demand
$e / ae$	PESS/GESS
$n / an / tn$	Power bus/gas node/heat node
$c$	Gas compressor
$l / al / tl$	Alias of power bus/gas note/heat node
$h / H$	Operation time index/final time interval

### 3) Parameters:

$C_g / C_e$	Operation costs for generators/ESS
$C_r / C_\ell$	Curtailment costs for renewables/demand
$P_{\ell,h} / U_{al,h}$	Electric/gas demand
$H_{tl,h}^L$	Heat demand

$P_g^{\max} / P_g^{\min}$	Maximum/minimum power capacity
$P_f^{\max}$	Maximum flow limit
$Y_f^{\max} / V_n^{\max}$	Current square/voltage square limit
$RU_g / RD_g$	Ramp up/down limits
$Ch_e / C\bar{h}_e$	ESS minimum/maximum charging limit
$Dh_e / D\bar{h}_e$	ESS minimum/maximum discharging limit
$\underline{SOC}_e$	ESS minimum SOC limit
$\overline{SOC}_e$	ESS maximum SOC limit
$SOC_{e,0}$	Initial ESS SOC
$LR_e$	Loss rate of the ESS
$\eta_e$	Charging and discharging efficiency
$X_{(f,ij)}$	Reactance of line $f$ or $ij$
$R_{(f,ij)}$	Resistance of line $f$ or $ij$
$B_h^\downarrow / B_h^\uparrow$	Downward/upward reserve requirement
$W_{an}^{\max}$	Maximum gas nodal pressure
$W_{an}^{\min}$	Minimum gas nodal pressure
$\beta_{ag}$	Gas-power conversion factor
$\gamma_c / \alpha_c$	Gas/inflow compressor factor
$\theta_{af}$	Weymouth coefficient
$U_{af,h}^{\max}$	Maximum gas procurement
$e$	Euler's number
$C_t$	Water specific heat capacity
$T_h$	Water pipeline ambient temperature
$\lambda_{tf}$	Heat transfer coefficient of water pipelines
$K_{tf}$	Length of water pipelines
$\bar{P}_{r,h}$	Uncertain renewable maximum power point

### 4) Variables:

$p_{g,h} / p_{r,h}$	Active power of generators/renewables
$q_{g,h} / q_{r,h}$	Reactive power of generators/renewables
$p_{e,h}$	Active power of PESSs
$p_{n,h} / q_{n,h}$	Nodal active/reactive power injection
$p_{n,h} / q_{n,h}$	Nodal active/reactive power injection
$p_{f,h}$	Active transmission power flow
$p_{mn,h} / q_{mn,h}$	Active/reactive distribution power flow
$soc_{e,h}$	SOC of ESSs
$s_{\ell,h} / s_{al,h}$	Electric/gas demand curtailment
$\delta_{n,h}$	Bus phase angle
$b_{g,h}^\uparrow / b_{g,h}^\downarrow$	Reserve capacity secured by generators
$p_{ag,h} / p_{tg,h}$	Active power output of gas unit/CHP
$q_{ag,h} / q_{tg,h}$	Reactive power output of gas unit/CHP
$u_{a,h} / u_{ae,h}$	Gas procurement/gas output from GESS
$u_{af,h}$	Inactive gas pipeline flow
$u_{af,h}^{cm,in}$	Inflow of gas compressors
$u_{af,h}^{cm,out}$	Outflow of gas compressors
$w_{an,h}$	Gas nodal pressure

$h_{tg,h}^S$	Heat consumption of CHP
$M_{tf,h}^{f,s}/M_{tf,h}^{f,r}$	Mass flow rate in supply/return pipeline
$M_{t,h}^s/M_{tl,h}^L$	Mass flow rate in heat source/load
$\tau_{tf,h}^{f,r}$	Temperature at inlet of the supply pipeline
$\tau_{tf,h}^{f,s}$	Temperature at outlet of the supply pipeline
$\tau_{tf,h}^{f,r}$	Temperature at inlet of the return pipeline
$\tau_{tf,h}^{f,s}$	Temperature at outlet of the return pipeline
$\tau_{tg,h}^S$	Heat source supply temperature
$\tau_{tg,h}^R$	Heat source return temperature
$\tau_{tl,h}^L$	Heat load supply temperature
$\tau_{tl,h}^R$	Heat load return temperature
$\tau_{tn,h}^{mix}$	Mixture temperature at supply node
$\tau_{tn,h}^{mix}$	Mixture temperature at return node

## I. INTRODUCTION

**E**LECTRICITY markets have been in a transitional stage that follows from a top-down hierarchy to a bottom-up one. As the local distribution networks and microgrids become increasingly active, they attain a growing capability to provide both power and ancillary service support to the upstream operator. While the transmission system could not overlook the local impacts, distribution system operators (DSOs) are emerging to seek cooperation with the conventional independent system operator (ISOs) for better managing a reliable and efficient power grid [1]. The variable distributed energy resource (DER) plays a critical role in this transition with governmental incentives and regulations, *e.g.*, FERC order 2222 [2]. Nevertheless, substantial operational uncertainties in DERs such as wind and solar variations shape a bottleneck when considering them in the market operation, especially with the transmission and distribution (T&D) coordination. The current research has conducted thorough investigations in the impacts of variable DERs in the power sector, *e.g.*, [3]. However, another non-negligible transition, *i.e.*, the proliferation of multi-energy carriers in the local energy network, is turning the power distribution system into a multi-energy hub. Its coordination with the T&D market hierarchy has not been sufficiently studied.

Existing literature has devoted considerable efforts to studying T&D coordination. Designing the future DSO frameworks gains prevalence since the ISO operation has been well structured and developed. As summarized in [4], there are three stages of the DSO design philosophy and its coordination scheme with the ISO, *i.e.*, centralized, decentralized, and transactive models. From first to last, the system of systems becomes more flexible and distributed. Due to the natural compatibility with the existing market framework, based on the distribution utility model (Model 3) in [4], our previous work [5] focuses on an ISO-leading unit commitment (UC) problem capturing the individual system uncertainties. The ISO still dominates the T&D market in this model, while the DSO performs as a utility managing the local assets. In this paper, we extend that work to investigate the case that both the ISO and DSO act as independent entities based on Model 4 in [4], where the ISO cannot easily dominate the coordinated market with no vision and control on DSOs. Entities only

exchange boundary information in the physical coupling node and operate independent market operations. There will no longer be an integrated UC problem as there is no central operator, but a multi-objective and multi-agent optimization problem, which could be formulated as a distributed economic dispatch (ED). We refer to [6] for deeper discussions on decentralized T&D cooperation.

The local energy system in the distribution level, however, does not only serve electric power. The proliferating energy hub in smart distribution systems houses multi-energy carriers, within which the electric power, natural gas, and heat energies are the most common and substantial [7]. It is natural that the DSO takes the multi-energy carriers' operations into account when coordinating with the power transmission system since other energy networks exert impacts on both system dynamics and techno-economic values of the power distribution system. However, the characteristics of each energy carrier are different and complex. For instance, the electric power flow in the power distribution system and the gas pipeline flow in the gas distribution system inflict nonlinearity and intractability to the coordinated market model. In our paper, to retain convexity, we propose using the second-order cone programming (SOCP) to model the nonlinear AC power flow and the gas flow equations while keeping the heat network linear via the variable-temperature constant-flow (VTCF) model. Note that it is normal to consider multi-energy carriers in the distribution system to be operated by a single entity, *i.e.*, the DSO. Many utilities manage and operate multi-energy assets, including power and gas, such as PG&E in California and ComEd in Illinois.

Operational uncertainties, *e.g.*, variable DER outputs, pose another hurdle in the T&D coordination. Though many works focus on the deterministic T&D operation due to the relatively small variation in the distribution network [8], [20], [21], it has been confirmed that a stochastic optimization-based model yield greater economic values and better capture the operation changes [10], [13]. Various stochastic optimization techniques have been widely applied in T&D coordination, among which the most common ones are scenario-based stochastic programming (SP) [5] and robust optimization (RO) [9]. The issue of the curse of dimensionality arises when the number of scenarios increases to capture enough uncertain patterns in the SP, and the over-conservatism of the RO beclouds its applicability in normal system operations. In this context, distributionally robust optimization (DRO) attracts extensive attention to achieve a tradeoff between conservativeness and uncertainty realization, which outperforms SP and RO as a general-use stochastic optimization framework [3]. It models the uncertainty by assuming an ambiguity set that approximates its true probability distribution, which enjoys broad applications in the literature. C. He *et al.* [22] adopted DRO modeling a power-gas energy hub operation considering electric and gas load uncertainties. D. Mohammadreza *et al.* [23] proposed a two-stage transactive energy framework using DRO to capture renewable DER uncertainties. P. Li *et al.* [10] built a DRO chance-constrained distributed T&D coordination problem with wind uncertainties.

The resulting T&D problem with energy hubs is highly

TABLE I  
COMPARISON BETWEEN THIS PAPER AND STATE-OF-THE-ART STUDIES

Domain	Reference	Problem	Network Modeling			Renewables	Operation	Method	Uncertainty Modeling
			Transmission	Distribution					
T&D	[8]	ED	Linear	Linear		✗	Decentralized	Gradient Decomposition	✗
	[9]	ED	Linear	Linear		✓	Decentralized	ADMM	RO
	[10]	ED	Linear	Linear		✓	Decentralized	Analytical Target Cascade	DRO
	[11]	ED	Linear	Nonlinear		✓	Centralized	SOCP	SP
	[12]	UC	Linear	Nonlinear		✗	Decentralized	Surrogate LR	✗
	[5]	UC	Linear	Nonlinear		✓	Decentralized	Nested L-shaped	SP
	[13]	ED	Linear	Nonlinear		✓	Decentralized	AAL	RO
	<b>This paper</b>	<b>ED</b>	<b>Linear</b>	<b>Nonlinear</b>		<b>✓</b>	<b>Decentralized</b>	<b>AAL</b>	<b>DRO</b>
Domain	Reference	Problem	Network Modeling			Operation	Method	Uncertainty Modeling	
			Power	Gas	Heat				
Energy Hub	[14]	UC	Linear	✗		VTCF	Centralized	SOCP	✗
	[15]	UC	Linear	Linear		✗	Centralized	Benders Decomposition	✗
	[16]	ED	Linear	Linear		Linear	Centralized	Linear Programming	SP
	[17]	ED	Linear	Nonlinear		✗	Decentralized	Benders Decomposition	✗
	[18]	ED	Linear	Nonlinear		✗	Centralized	Dual Reformulation	DRO
	[19]	ED	Linear	✗		VTCF	Decentralized	ADMM	✗
	[7]	ED	Linear	Nonlinear		VTCF	Decentralized	ADMM	✗
	<b>This paper</b>	<b>ED</b>	<b>Nonlinear</b>	<b>Nonlinear</b>		<b>VTCF</b>	<b>Decentralized</b>	<b>AAL</b>	<b>DRO</b>

Note: Please find acronym expansions in the text.

intractable due to the multi-scale T&D system characteristics and the stochastic nature of DERs. Meanwhile, when the ISO and DSO act as independent entities, they should execute individual scheduling problems with the privacy of system information preserved during the operation. Hence, centralized decomposition techniques such as Benders decomposition [15] are not applicable. Instead, ISOs and DSOs require distributed algorithms to decentralize communications such as the well-known augmented Lagrangian relaxation (LR) method. It helps each agent formulate the individual subproblem and only updates Lagrangian multipliers, *i.e.*, gradient information, in each iteration, protecting agents' confidentiality. A recent enhancement, *i.e.*, the accelerated augmented Lagrangian (AAL) [24], becomes a more efficient alternative than conventional LR-based methods such as the alternating direction of multipliers method (ADMM). Though originally devised for solving nonconvex problems, the efficacy of the AAL has also been validated in distributed convex applications with better performance than ADMM [25]. To solve the DRO-based subproblems for the ISO and DSOs, we propose using the widely-adopted column-and-constrained generation (C&CG) method [26], which is embedded in the AAL procedure without jeopardizing the convergence.

Though the existing literature has conducted thorough research in the T&D operation and distribution-level energy hubs, to the best of the authors' knowledge, this is the first work investigating the impacts of multi-energy hubs in the T&D electricity market. We also extend the application of AAL to the DRO, which yields better performance and economic outcomes than deterministic [25] and RO [13] applications. We conduct a comprehensive comparison between

this study and other recent works in Table I. Furthermore, we summarize the threefold contributions of this paper as follows.

- We propose a novel multi-period scheduling framework for coordination between the transmission system and local energy hubs. The energy hub considers electric, gas, and heat energies with explicit network and resource modeling. The quantitative analyses demonstrate the cost-effectiveness of considering multi-energy hubs in T&D coordination.
- We implement a T&D market paradigm based on decentralized operations, which serves as a potential future T&D market structure as discussed in [4]. Each agent considers individualized uncertainties such as renewable generation and multi-energy demand without impacting others.
- We tailor the AAL algorithm with the C&CG method and validates its applicability to a DRO-based multi-agent distributed operation. The proposed method meets the requirements for solving a stochastic T&D coordination problem, *e.g.*, computational efficiency, convergence guarantee, and privacy protection.

We organize the rest of the paper as follows. Section II provides a detailed problem formulation for the transmission system operation and the local energy hub scheduling while also introducing the ambiguity set construction for each system's uncertainties; section III describes the decentralization between agents and the overall solution procedure of the distributionally robust T&D problem based on the AAL algorithm; section IV demonstrates the effectiveness of the proposed framework using numerical experiments; section V concludes the paper with several technical remarks.

## II. PROBLEM FORMULATION OF THE DRO-BASED MULTI-ENERGY T&D COORDINATION

In this section, we detail the mathematical formulation of the transmission system and local energy hubs, with uncertainties involved in the variable renewable generation. A two-agent co-optimization describes the T&D coordination with different agent-specific modeling details. We consider the upstream agent problem as a conventional economic dispatch carried out for the transmission network with industry-calibrated DC power flow. The problem for downstream agents is an SOCP-based multi-energy hub optimization considering nonlinear network equations for more accurate AC power and gas pipeline flows. The heat network brings a linearized VTCF model. Both agents follow a two-stage distributionally robust optimization formulation with individualized ambiguity sets for uncertainties.

### A. Upstream Agent Problem: Transmission Market

The upstream agent solves a transmission ED problem capturing utility-level wind uncertainties. We write a canonical form of the formulation as shown in (1).

$$\begin{aligned} \mathcal{T} := & \min_{\mathbf{x}^T} \sum_h \left[ \sum_{g^T} C_g^T p_{g,h}^T + \sum_{e^T} C_e^T (c_{e,h}^T + d_{e,h}^T) \right] \\ & + \sup_{P^T \in \mathcal{A}^T} \mathbb{E}_{P^T} \left\{ \min_{\mathbf{y}^T} \sum_h \left[ \sum_{r^T} C_r^T b_{r,h}^T + \sum_{\ell^T} C_\ell^T s_{\ell,h}^T \right] \right\} \end{aligned} \quad (1a)$$

subject to

$$\begin{aligned} & \sum_{g^T \in A(n^T)} p_{g,h}^T + \sum_{r^T \in A(n^T)} p_{r,h}^T - \sum_{f^T \in S(n^T)} p_{f,h}^T \\ & + \sum_{f^T \in N(n^T)} p_{f,h}^T + \sum_{e^T \in A(n^T)} p_{e,h}^T = \sum_{\ell^T \in A(\ell^T)} \{ P_{\ell,h}^T - s_{\ell,h}^T \}, \end{aligned} \quad \forall n^T, \forall h, \quad (1b)$$

$$p_{f,h}^T = X_{f^T}^{-1} [\delta_n^T |_{S(n^T)=f^T,h} - \delta_n^T |_{N(n^T)=f^T,h}], \forall f^T, \forall h, \quad (1c)$$

$$-P_f^{T,\max} \leq p_{f,h}^T \leq P_f^{T,\max}, \quad \forall f^T, \forall h, \quad (1d)$$

$$p_{g,h}^T - p_{g,h-1}^T \leq RU_g^T, \quad \forall g^T, \forall h, \quad (1e)$$

$$p_{g,h-1}^T - p_{g,h}^T \leq RD_g^T, \quad \forall g^T, \forall h, \quad (1f)$$

$$P_g^{T,\min} \leq p_{g,h}^T \leq P_g^{T,\max}, \quad \forall g^T, \forall h, \quad (1g)$$

$$P_g^{T,\min} + b_{g,h}^{T,\downarrow} \leq p_{g,h}^T \leq P_g^{T,\max} + b_{g,h}^{T,\uparrow}, \quad \forall g^T, \forall h, \quad (1h)$$

$$\sum_{g^T} b_{g,h}^{T,\downarrow} \geq B_h^{T,\downarrow}; \quad \sum_{g^T} b_{g,h}^{T,\uparrow} \geq B_h^{T,\uparrow} \quad \forall h, \quad (1i)$$

$$b_{r,h}^T = \tilde{P}_{r,h}^T - p_{r,h}^T \quad \forall r^T, \forall h, \quad (1j)$$

where  $\mathbf{x}^T = \{p_{g,h}^T, p_{r,h}^T, p_{e,h}^T, c_{e,h}^T, d_{e,h}^T\}$  is the first-stage decision variable vector and  $\mathbf{y}^T = \{m_{g,h}^T, s_{\ell,h}^T\}$  is the second-stage decision variable vector. Formulation (1) follows a typical day-ahead ED model, including the power balance equation (1b), DC power flow equation (1c), flow capacity constraint (1d), ramping constraints (1e)-(1f), power capacity constraint (1g), upward/downward reserve limit constraint (1h), reserve

requirements (1i), and renewable curtailment equation (1j). We slightly abuse the notation of subscript  $\mathcal{T}$  in sets and variables for readability. We also defer the ESS model in the transmission system to Section III. C with a generalized formulation. Note that we adopt the DC power flow to increase the proposed model's compatibility with the current ISO's practice [27]. In the objective function (1a), the first-stage cost contains the power generation cost and energy storage system (ESS) degradation cost, and the renewable curtailment cost and load shedding cost remain in the second stage. It is natural to regard the first stage as a normal market clearing and the second stage as an *ex post* adjustment during the operation. Though we utilize linear cost coefficients in the objective for showcase, it could adapt to more practical designs such as the quadratic cost curve and more sophisticated ESS degradation processes, which is out of the scope of this study and requires unique treatments in the decentralization process. In this case, the upstream agent features two-stage stochastic linear programming.

### B. Downstream Agent Problem: Multi-Energy Hub

The downstream agent solves a distribution ED problem capturing DER-level uncertainties. However, the synergy between electric power, gas, and heat energies far complicates the problem than the upstream agent.

$$\begin{aligned} \mathcal{D} := & \min_{\mathbf{x}^D} \mathcal{C}_g^D(\mathbf{p}_{g,h}^D) + \mathcal{C}_e^D(\mathbf{p}_{e,h}^D) + \\ & \sup_{P^D \in \mathcal{A}^D} \mathbb{E}_{P^D} \left\{ \min_{\mathbf{y}^D} \mathcal{C}_r^D(\mathbf{b}_{r,h}^D) + \mathcal{C}_\ell^D(\mathbf{s}_{\ell,h}^D) \right\}, \end{aligned} \quad (2a)$$

subject to

$$\text{Constraints (3a)-(3n), (4a)-(4g), (5a)-(5h), (6a)-(6f),} \quad (2b)$$

where

$$\mathcal{C}_g^D(\mathbf{p}_{g,h}^D) = \sum_h \left[ \sum_{g^D} C_g^D p_{g,h}^D + \sum_{ag} C_{a,u_{a,h}} + \sum_{tg} C_{tg} p_{tg,h}^D \right],$$

$$\mathcal{C}_e^D(\mathbf{p}_{e,h}^D) = \sum_h \left[ \sum_{e^D} C_e^D (c_{e,h}^D + d_{e,h}^D) + \sum_{ae} C_{ae} (c_{ae,h} + d_{ae,h}) \right],$$

$$\mathcal{C}_r^D(\mathbf{b}_{g,h}^D) = \sum_h \sum_{r^D} C_r^D b_{r,h}^D, \quad \text{and}$$

$$\mathcal{C}_\ell^D(\mathbf{s}_{\ell,h}^D) = \sum_h \left[ \sum_{\ell^D} C_\ell^D s_{\ell,h}^D + \sum_{al} C_{al} s_{al,h} \right]$$

denote the production costs (including power generation cost, gas procurement cost, and combined heat and power (CHP) generation cost), multi-energy ESS degradation costs, DER curtailment costs, and multi-energy load shedding costs, respectively. Note that the first stage and second stage follow the same structure as in the upstream agent with a similar ambiguity set construction, which will be detailed in Section III. D. Based on different energy systems' characteristics, we sectionalize the constraint space for electric power, natural gas, and heat systems as follows. Besides, note that the convexification of multi-energy network flow models is necessary for finding a convergent solution, yet retains exactness, which has been corroborated in various studies [5], [28], [29].

1) *Electric Power Distribution Network*: We cast the SOCP-based AC branch flow model [5] in the power distribution system with generation constraints.

$$P_g^{\mathcal{D},\min} \leq p_{g,h}^{\mathcal{D}} \leq P_g^{\mathcal{D},\max}, \quad \forall g^{\mathcal{D}}, \forall h, \quad (3a)$$

$$P_g^{\mathcal{D},\min} + b_{g,h}^{\mathcal{D},\downarrow} \leq p_{g,h}^{\mathcal{D}} \leq P_g^{\mathcal{D},\max} + b_{g,h}^{\mathcal{D},\uparrow}, \quad \forall g^{\mathcal{D}}, \forall h, \quad (3b)$$

$$p_{g,h}^{\mathcal{D}} - p_{g,h-1}^{\mathcal{D}} \leq RU_g^{\mathcal{D}}, \quad \forall g^{\mathcal{D}}, \forall h, \quad (3c)$$

$$p_{g,h-1}^{\mathcal{D}} - p_{g,h}^{\mathcal{D}} \leq RD_g^{\mathcal{D}}, \quad \forall g^{\mathcal{D}}, \forall h, \quad (3d)$$

$$b_{r,h}^{\mathcal{D}} = \tilde{P}_{r,h}^{\mathcal{D}} - p_{r,h}^{\mathcal{D}}, \quad \forall r^{\mathcal{D}}, \forall h, \quad (3e)$$

$$0 \leq y_{nl,h}^{\mathcal{D}} \leq Y_{nl}^{\mathcal{D},\max} \quad \forall (n^{\mathcal{D}}, l^{\mathcal{D}}) \in L, \forall h, \quad (3f)$$

$$(p_{nl,h}^{\mathcal{D}})^2 + (q_{nl,h}^{\mathcal{D}})^2 \leq y_{nl,h}^{\mathcal{D}} v_{l,h}, \quad \forall (n^{\mathcal{D}}, l^{\mathcal{D}}) \in L, \forall h, \quad (3g)$$

$$\sum_{g^{\mathcal{D}}} b_{g,h}^{\mathcal{D},\downarrow} \geq B_h^{\mathcal{D},\downarrow}; \quad \sum_{g^{\mathcal{D}}} b_{g,h}^{\mathcal{D},\uparrow} \geq B_h^{\mathcal{D},\uparrow} \quad \forall h, \quad (3h)$$

$\forall n^{\mathcal{D}}, \forall h$ :

$$p_{n,h}^{\mathcal{D}} = \sum_{k:n \rightarrow k} p_{nk,h}^{\mathcal{D}} - \sum_{j:j \rightarrow n} (p_{nj,h}^{\mathcal{D}} - R_{nj} y_{nj,h}^{\mathcal{D}}), \quad (3i)$$

$$q_{n,h}^{\mathcal{D}} = \sum_{k:n \rightarrow k} q_{nk,h}^{\mathcal{D}} - \sum_{j:j \rightarrow n} (q_{nj,h}^{\mathcal{D}} - X_{nj} y_{nj,h}^{\mathcal{D}}), \quad (3j)$$

$$v_{n,h} - v_{l,h} = (R_{nl}^2 + X_{nl}^2) y_{nl,h}^{\mathcal{D}} - 2(R_{nl} p_{nl,h}^{\mathcal{D}} + X_{nl} q_{nl,h}^{\mathcal{D}}), \quad (3k)$$

$$\begin{aligned} p_{n,h}^{\mathcal{D}} &= \sum_{g^{\mathcal{D}} \in A(n^{\mathcal{D}})} p_{g,h}^{\mathcal{D}} + \sum_{ag \in A(n^{\mathcal{D}})} p_{ag,h} \\ &+ \sum_{tg \in A(n^{\mathcal{D}})} p_{tg,h} + \sum_{r^{\mathcal{D}} \in A(n^{\mathcal{D}})} p_{r,h}^{\mathcal{D}} + \sum_{e^{\mathcal{D}} \in A(n^{\mathcal{D}})} p_{e,h}^{\mathcal{D}} \\ &\quad - \sum_{\ell^{\mathcal{D}} \in A(n^{\mathcal{D}})} \{P_{\ell,h}^{\mathcal{D}} - s_{\ell,h}^{\mathcal{D}}\}, \end{aligned} \quad (3l)$$

$$\begin{aligned} q_{n,h}^{\mathcal{D}} &= \sum_{g^{\mathcal{D}} \in A(n^{\mathcal{D}})} q_{g,h}^{\mathcal{D}} + \sum_{ag \in A(n^{\mathcal{D}})} q_{ag,h} + \sum_{tg \in A(n^{\mathcal{D}})} q_{tg,h} \\ &+ \sum_{r^{\mathcal{D}} \in A(n^{\mathcal{D}})} q_{r,h}^{\mathcal{D}} - \sum_{\ell^{\mathcal{D}} \in A(n^{\mathcal{D}})} Q_{\ell,h}^{\mathcal{D}}, \end{aligned} \quad (3m)$$

$$V_n^{\min} \leq v_{n,h} \leq V_n^{\max}. \quad (3n)$$

The power distribution model constrains power capacity (3a), reserve capacity (3b), ramp capability (3c)-(3d), renewable curtailment (3e), current flow (3f)-(3g), reserve requirement (3h), AC power flow with an active and reactive power balance (3i)-(3m), and nodal voltage (3n). We assume the distribution network operates in normal conditions with radiality. Note that we consider neither reactive power support from ESSs nor reactive power exchange in the boundary node for simplicity.

2) *Natural Gas Distribution Network*: We adopt the SOCP-based Weymouth equation in the gas network model.

$$W_{an}^{\min} \leq w_{an,h} \leq W_{an}^{\max}, \quad \forall an, \forall h, \quad (4a)$$

$$u_{a,h} \leq U_{a,h}^{\max}, \quad \forall a, \forall h, \quad (4b)$$

$$w_{an,h} \leq \gamma_c \cdot w_{ak,h}, \quad \forall (an, ak) \subseteq c, \forall h, \quad (4c)$$

$$U_{af}^{\min} \leq u_{af,h} \leq U_{af}^{\max}, \quad \forall af, \forall h, \quad (4d)$$

$$(1 - \alpha_c) u_{af,h}^{cm,in} = u_{af,h}^{cm,out}, \quad \forall c \in af, \forall h, \quad (4e)$$

$$u_{af,h}^2 \leq \theta_{af} \cdot (w_{an,h}^2 - w_{al,h}^2), \quad \forall an \subseteq af, \forall h, \quad (4f)$$

$$\begin{aligned} &\sum_{a \in A(an)} u_{a,h} + \sum_{af \in N(an)} u_{af,h} - \sum_{af \in S(an)} u_{af,h} \\ &+ \sum_{af \in N(an)} u_{af,h}^{cm,in} - \sum_{a \in S(an)} u_{af,h}^{cm,out} + \sum_{ae \in A(an)} u_{ae,h} \\ &= \sum_{al \in A(an)} (U_{al,h} - s_{al,h}) + \sum_{ag \in A(an)} p_{ag,h} \cdot \beta_{ag}, \end{aligned} \quad \forall an, \forall h, \quad (4g)$$

The gas distribution model constrains nodal gas pressure (4a), gas well procurement (4b), compressor ratio (4c), gas flow limit (4d), compressor in/out flow (4e), SOCP-relaxed Weymouth equation (4f), and gas load balance (4g). Note that we follow the approximation in [28] for linearizing the nonconvex model of the gas compressor.

3) *Heat Distribution Network*: We consider a linear VTCF heat network model with guaranteed accuracy [29] as follows.

$$H_{tg,h}^S = C_t M_{tg,h}^S (\tau s_{tg,h}^S - \tau r_{tg,h}^S), \quad \forall tg, \forall h, \quad (5a)$$

$$H_{tl,h}^L = C_t M_{tl,h}^L (\tau s_{tl,h}^L - \tau r_{tl,h}^L), \quad \forall tl, \forall h, \quad (5b)$$

$$\tau s_{tf,h}^{f,r} = (\tau s_{tf,h}^{f,s} - T_h) e^{-\frac{\lambda_{tf} K_{tf}}{C_t M_{tf,h}^{f,s}}} + T_h, \quad \forall tf, \forall h, \quad (5c)$$

$$\tau r_{tf,h}^{f,r} = (\tau r_{tf,h}^{f,s} - T_h) e^{-\frac{\lambda_{tf} K_{tf}}{C_t M_{tf,h}^{f,s}}} + T_h, \quad \forall tf, \forall h, \quad (5d)$$

$\forall tn, \forall h$ :

$$\sum_{tf \in N(tn)} M_{tf,h}^{f,s} + \sum_{t \in A(tn)} M_{t,h}^S = \sum_{tf \in S(tn)} M_{tf,h}^{f,s} + \sum_{tl \in A(tn)} M_{tl,h}^L, \quad (5e)$$

$$\sum_{tf \in N(tn)} M_{tf,h}^{f,r} + \sum_{tl \in A(tn)} M_{tl,h}^L = \sum_{tf \in S(tn)} M_{tf,h}^{f,r} + \sum_{t \in N(tn)} M_{t,h}^S, \quad (5f)$$

$$\begin{aligned} &\sum_{tf \in N(tn)} \tau s_{tf,h}^{f,r} M_{tf,h}^{f,s} + \sum_{t \in A(tn)} \tau s_{t,h}^S M_{t,h}^S = \\ &\tau s_{tn,h}^{mix} \left( \sum_{tf \in N(tn)} M_{tf,h}^{f,s} + \sum_{t \in A(tn)} M_{t,h}^S \right), \end{aligned} \quad (5g)$$

$$\begin{aligned} &\sum_{tf \in S(tn)} \tau r_{tf,h}^{f,r} M_{tf,h}^{f,s} + \sum_{tl \in A(tn)} \tau r_{tl,h}^L M_{tl,h}^L \\ &= \tau r_{tn,h}^{mix} \left( \sum_{tf \in S(tn)} M_{tf,h}^{f,s} + \sum_{tl \in A(tn)} M_{tl,h}^L \right), \end{aligned} \quad (5h)$$

with the heat pipeline loss defined as

$$\begin{aligned} \Delta \mathcal{L}_{tf,h} &= C_t M_{tf,h}^{f,s} (\tau s_{tf,h}^{f,r} - \tau s_{tf,h}^{f,s}) \\ &\triangleq \lambda_{tf} K_{tf} (\tau s_{tf,h}^{f,s} - T_h). \end{aligned}$$

The heat network model follows a typical VTCF formulation constraining the thermal energy conversion with temperature (5a)-(5b), confluence nodal temperatures (5c)-(5d), mass flow

balance (5e)-(5f), and heat inlet/outlet flow-temperature (5g)-(5h). We perform a heuristic two-step hydraulic-thermal decomposition to fix the mass flow rate  $M$  and hence reduce the heat network model to a linear formulation, which reportedly maintains accuracy. We refer to [29] for detailed descriptions of the heuristic and the derivation of (5). Note that, unlike the power and gas system, formulating the heat system dynamics in (5) maintains the computational tractability while providing a more accurate representation of the network. Besides, the acceptably accurate representation and excellent solvability of the VTCF model underly the motivation for using it in the proposed coordinated energy hub analysis. For the CHP operations, we adopt the convex polyhedron to model CHP heat and power curves as discussed in our previous work [30], which retains model convexity and is omitted here.

### C. Energy Storage Operations

As the proposed framework considers the power ESS (PESS) in transmission and distribution systems and the gas ESS (GESS) in distribution systems, we discuss the ESS model with a general formulation, *i.e.*,  $p_{e,h}^{(T,D)} = \{p_{e,h}^T, p_{e,h}^D, u_{ae,h}\}$ .

$$p_{e,h}^{(T,D)} = d_{e,h}^{(T,D)} - c_{e,h}^{(T,D)}, \quad \forall e^{(T,D)}, \forall h, \quad (6a)$$

$$\underline{Ch}_e^{(T,D)} \leq c_{e,h}^{(T,D)} \leq \overline{Ch}_e^{(T,D)}, \quad \forall e^{(T,D)}, \forall h, \quad (6b)$$

$$\underline{Dh}_e^{(T,D)} \leq d_{e,h}^{(T,D)} \leq \overline{Dh}_e^{(T,D)}, \quad \forall e^{(T,D)}, \forall h, \quad (6c)$$

$$\begin{aligned} \text{soc}_{e,h}^{(T,D)} - (1 - LR_e^{(T,D)})\text{soc}_{e,h-1}^{(T,D)} \\ = c_{e,h}^{(T,D)} \cdot \eta_e^{(T,D)} - d_{e,h}^{(T,D)} / \eta_e^{(T,D)}, \quad \forall e^{(T,D)}, \forall h, \end{aligned} \quad (6d)$$

$$\underline{SOC}_{e,h}^{(T,D)} \leq \text{soc}_{e,h}^{(T,D)} \leq \overline{SOC}_{e,h}^{(T,D)}, \quad \forall e^{(T,D)}, \forall h, \quad (6e)$$

$$\text{SOC}_{e,0}^{(T,D)} = \text{soc}_{e,H}^{(T,D)}, \quad \forall e^{(T,D)}, \quad (6f)$$

which includes ESS power equations (6a), charge/discharge limits (6b)-(6c), state-of-charge (SOC) equations (6d), SOC limits (6e), and SOC consistency requirements (6f). Note that it is not necessary to include the binary exclusiveness for battery charging/discharging since it could be achieved by the efficiency implementation and ESS operation price [31].

### D. Ambiguity Set Construction

The uncertainty studied in this work includes the variable renewable energy, while it could seamlessly extend to other uncertainties such as load and price. We employ the Wasserstein distance for the ambiguity set construction. Note that it works for both transmission and distribution systems. Consider the uncertain renewable output  $\hat{P}_{r,h}$  has a series of historical observations  $\{\hat{P}_{r,h}^1, \hat{P}_{r,h}^2, \dots, \hat{P}_{r,h}^E\}$ . Given the compact support space  $\Xi = \{\hat{P}_{r,h} \in \mathbb{R}^+\}$ , whose  $\sigma$ -algebra contains the true and empirical renewable generation probability distributions, *i.e.*,  $\mathbb{P}, \mathbb{P}^E \in \mathcal{P}(\Xi)$ , we define the Wasserstein metric as

$$D_w(\mathbb{P}, \mathbb{P}^E) := \inf_{\Pi} \left\{ \int \|\tilde{P}_{r,h}, \hat{P}_{r,h}^E\| \Pi(d\tilde{P}_{r,h}, d\hat{P}_{r,h}^E) \right\},$$

where  $\Pi$  denotes the joint probability distribution. Then we construct the ambiguity set as

$$\mathcal{A} := \left\{ \mathbb{P} \in \mathcal{P}(\Xi) \mid D_w(\mathbb{P}, \mathbb{P}^E) \leq \phi(E) \right\},$$

where  $\phi(E)$  is a tunable Wasserstein ball radius and  $\mathbb{P}^E$  serves as the centroid of  $\mathcal{A}$ . It is crucial that  $\phi(E)$  controls the conservativeness of the ambiguity set and we follow an improved criterion for its selection [32], *i.e.*,

$$\phi(E) = C \sqrt{\frac{1}{E} \ln \frac{1}{1-\kappa}},$$

where  $\kappa$  is the confidence level, for which we typically use 95% in this study, and  $C$  is a scalar obtained by using the bisection search method [32] to solve

$$C = \inf_{\rho \geq 0} 2 \sqrt{\frac{1}{2\rho} \left[ 1 + \ln \left( \mathbb{E} \{ e^{\rho \| \hat{P}_{r,h}^E - M(\hat{P}_{r,h}^E) \|} \} \right) \right]},$$

where  $M(\hat{P}_{r,h}^E)$  denotes the mean value of observations.

## III. T&D DECENTRALIZATION AND SOLUTION STRATEGY

The proposed distributionally robust T&D problem indicates a multi-agent and multi-objective optimization, which is hard to solve as each agent presents a two-stage DRO problem with independent ambiguity sets for uncertainties. In this section, we delineate how we solve the individual subproblem via the tailored C&CG method and decentralize the overall coordination problem using the AAL algorithm.

### A. DRO Subproblem Reformulation and Solution

As linear programming is a special case of SOCP, we give a compact form for both (1) and (2) with uncertainty  $\omega$  and without T&D superscripts as follows.

$$\forall \mathcal{T}, \forall \mathcal{D} : \min_{\mathbf{x}} \mathbf{c}^\top \mathbf{x} + \sup_{\omega \in \mathcal{A}} \mathbb{E}_\omega \{ Q(\mathbf{y}, \omega) \}, \quad (7a)$$

subject to

$$\|\mathbf{A}\mathbf{x} + \mathbf{B}\mathbf{y} + \mathbf{k}\|_2 \leq \mathbf{q}^\top \mathbf{x} + \mathbf{p}^\top \mathbf{y} + \mathbf{h}, \quad (7b)$$

$$Q(\mathbf{y}, \omega) = \min_{\mathbf{y}} \mathbf{d}^\top \mathbf{y}, \quad (7c)$$

$$\mathbf{E}\mathbf{x} + \mathbf{F}\mathbf{y} + \mathbf{G}\omega \leq \mathbf{m}, \quad (7d)$$

where (7b) and (7d) constrain the first- and second-stage problems. We first reformulate the Wasserstein metric as

$$\begin{aligned} D_w(\mathbb{P}, \mathbb{P}^E) &= \inf_{\Pi} \left\{ \int_{\omega} \|\omega, \omega^E\| \Pi(d\omega, d\omega^E) \right\}, \\ &= \inf_{\mathbb{P}} \left\{ \int_{\omega} \mathbb{E}_\omega \|\omega, \omega^E\| \mathbb{P}(d\omega) \right\}, \end{aligned} \quad (8)$$

where  $\mathbb{P}(d\omega)$  denotes the probability distribution when  $\omega$  falls in the centroid of  $\mathcal{A}$ , given the conditional distribution  $\Pi(d\omega, d\omega^E) = \mathbb{E}\{\mathbb{P}(d\omega)\}$ . Based on (8), we rewrite the second stage with the ambiguity set as a semi-infinite program

$$\sup_{\omega \in \mathcal{A}} \mathbb{E}_\omega \{ Q(\mathbf{y}, \omega) \} = \max_{\mathbb{P}(d\omega)} \int_{\omega} \mathbb{E}_\omega \{ Q(\mathbf{y}, \omega) \cdot \mathbb{P}(d\omega) \}, \quad (9a)$$

subject to

$$\int_{\omega} \mathbb{P}(d\omega) = \mathbf{1} \quad : \boldsymbol{\mu}_\omega, \quad (9b)$$

$$\int_{\omega} \mathbb{E}_\omega \{ \|\omega, \omega^E\| \} \mathbb{P}(d\omega) \leq \phi(E) \quad : \zeta. \quad (9c)$$




Fig. 1. Decentralized solution workflow by the C&CG-embedded AAL.

As problem (9) is always bounded with finite observations of  $\omega$ , it is equivalent to dualize (9a) and replace the second stage problem, which yields

$$\min_{\mathbf{x}, \boldsymbol{\mu}_\omega, \zeta, \boldsymbol{\delta}_\omega} \mathbf{c}^\top \mathbf{x} + \mathbb{E}_\omega \{ \boldsymbol{\mu}_\omega + \zeta \cdot \phi(E) \}, \quad (10a)$$

subject to

$$\| \mathbf{A}\mathbf{x} + \mathbf{B}\mathbf{y} + \mathbf{k} \|_2 \leq \mathbf{q}^\top \mathbf{x} + \mathbf{p}^\top \mathbf{y} + \mathbf{h}, \quad (10b)$$

$$\| \boldsymbol{\delta}_\omega \|_\infty \leq \zeta, \quad (10c)$$

$$\boldsymbol{\mu}_\omega \geq \max_\omega \{ Q(\mathbf{y}, \omega) - \boldsymbol{\delta}_\omega^\top (\omega - \omega^E) \}, \quad (10d)$$

$$Q(\mathbf{y}, \omega) = \min_{\mathbf{y}} \{ \mathbf{d}^\top \mathbf{y} \}, \quad (10e)$$

$$\mathbf{E}\mathbf{x} + \mathbf{F}\mathbf{y} + \mathbf{G}\boldsymbol{\omega} \leq \mathbf{m}, \quad (10f)$$

where the auxiliary variable  $\boldsymbol{\delta}_\omega$  is introduced to bound the dual norm [33]. We could efficiently solve problem (10) via the C&CG algorithm tailored in [34]. Note that we place the SOCP constraints in the first stage to generate an exact lower-bounding affine cut from the second stage, which accelerates the optimal searching of the algorithm.

### B. Decentralized T&D Information Exchange

After each DRO-based subproblem is solved, we present a more general form for the revisited master problem in the C&CG method upon convergence as

$$\forall \mathcal{T}, \forall \mathcal{D} : \min_{\mathbf{x}} \mathcal{F}(\mathbf{x}, \mathbf{x}_C), \quad (11a)$$

subject to

$$\mathcal{G}(\mathbf{x}, \mathbf{x}_C) \leq 0, \quad (11b)$$

$$\mathcal{H}(\mathbf{x}, \mathbf{x}_C) = 0, \quad (11c)$$

where  $\mathbf{x}_C$  denotes the common variables shared in the T&D coordination, *e.g.*, power injection at the boundary node. Consider a centralized model including all agents' operations,

$$\min_{\mathbf{x} \in \Psi} \mathcal{F}^\mathcal{T}(\mathbf{x}^\mathcal{T}, \mathbf{x}_C^\mathcal{T}) + \sum_{\mathcal{D}} \mathcal{F}^\mathcal{D}(\mathbf{x}^\mathcal{D}, \mathbf{x}_C^\mathcal{D}), \quad (12a)$$

subject to

$$\mathbf{x}_C^\mathcal{T} = \mathbf{x}_C^\mathcal{D}, \quad (12b)$$

where  $\Psi$  describes the T&D feasible region and (12b) unifies the common variables. It is straightforward to write the




Fig. 2. Network topology of the test system [35], [36].

individual Lagrangian functions for both agents as

$$\mathcal{L}^\mathcal{T} := \mathcal{F}^\mathcal{T}(\mathbf{x}^\mathcal{T}, \mathbf{x}_C^\mathcal{T}) + \sum_{\mathcal{D}} \boldsymbol{\lambda}^\mathcal{D} (\mathbf{x}_C^\mathcal{T} - \hat{\mathbf{x}}_C^\mathcal{D}) + \frac{\nu}{2} \|\mathbf{x}_C^\mathcal{T} - \hat{\mathbf{x}}_C^\mathcal{D}\|_2, \quad (13a)$$

$$\mathcal{L}^\mathcal{D} := \mathcal{F}^\mathcal{D}(\mathbf{x}^\mathcal{D}, \mathbf{x}_C^\mathcal{D}) + \boldsymbol{\lambda}^\mathcal{D} (\hat{\mathbf{x}}_C^\mathcal{T} - \mathbf{x}_C^\mathcal{D}) + \frac{\nu}{2} \|\hat{\mathbf{x}}_C^\mathcal{T} - \mathbf{x}_C^\mathcal{D}\|_2, \quad (13b)$$

where  $\boldsymbol{\lambda}^\mathcal{D}$  defines the Lagrangian multipliers for the common variable shared by each distribution network and  $\nu$  is the second-order penalty step size. Then following Fig. 1, we perform the AAL algorithm and solve each agent's problem in parallel. The merits of AAL include the double updates in one iteration and the acceleration brought by using  $\nu$  in both updates for primal variables and Lagrangian multipliers, which outperforms other optimality-conditioned methods [24].

Similar to [13], the subproblem's solution process and the AAL are independent. However, the AAL's convergence depends on the convergence of the inner C&CG process, which is guaranteed by model convexity and linear recourse problems with finite support. This feature protects each agent's privacy as the solution processes do not cross impact with only limited information, *e.g.*, boundary power injection, being exchanged.

TABLE II  
COMPARISONS BETWEEN THE THREE CASES RESULTS

	Case 1	Case 2	Case 3
<b>Transmission Cost</b>	\$27,293.1	\$27,371.9	\$32,116.8
- Generation	\$26,229.4	\$26,431.7	\$31,599.2
- ESS	\$1,063.7	\$940.2	\$517.6
- Load Shed	0	0	0
<b>Distribution Cost</b>	\$3,855.6	\$4,262.1	\$5,506.2
• Power Network	-\$2,294.9	\$4,262.1	\$5,506.2
- Generation	0	\$4,889.2	\$5,416.8
- ESS	\$144.7	\$150.2	\$89.4
- Load Shed	0	0	0
- Trade Revenue	-\$2,439.6	-\$777.4	-
• Gas Network	\$5,110.9	-	-
- Generation	\$5,002.3	-	-
- ESS	\$108.6	-	-
- Load Shed	0	-	-
• Heat Network	\$1,039.6	-	-
- Generation	\$1,039.6	-	-
- ESS	-	-	-
- Load Shed	0	-	-
<b>Avg. Power Mismatch</b>	0%	0%	23.8%
<b>Network Loss</b>	7.15MWh	10.47MWh	10.47MWh
<b>Renewable Curtailment</b>	1.39%	3.54%	10.73%

#### IV. NUMERICAL EXPERIMENTS

In this section, we validate the effectiveness of the proposed market paradigm and solution strategy via quantitative analyses on a standard test system. We carry out case studies on the IEEE 6-bus transmission system connecting to two multi-energy hubs based on the IEEE 13-bus distribution system, whose data could be retrieved from [35]–[37]. Fig. 2 illustrates the test system’s topology. We solve all of the SOCP subproblems by Gurobi 9.1 on a Windows PC with quad-core Intel i7-6700 CPU and 8GB of RAM.

For the renewable uncertainty considered in the proposed model, we normalize the historical data from a utility-level wind turbine [38], and two DER-level photovoltaic panels [39]. Then we construct the ambiguity set following the procedure described in Section II. D. for each distribution network. Note that for different distribution systems, the ambiguity set is independent since the training datasets from the historical observations are *i.i.d.* For the AAL algorithm, we set  $\varepsilon_1, \varepsilon_2 = 0.01$  and select  $\iota = 0.25$  and  $\nu = 2.2$ , fine-tuned by computational trials.

##### A. Cost-effectiveness of Considering Multi-Energy Hubs

We first validate the cost-effectiveness of considering multi-energy hubs by comparing the following cases.

- Case 1. T&D coordination with multi-energy hubs
- Case 2. T&D coordination with only power distribution
- Case 3. Disconnected T&D operations

For Case 2, we do not model the gas and heat distribution networks, while gas-fired generators  $ag_1, ag_2$  use the normalized gas fuel prices, and CHP is assumed as a linear-cost generator. For Case 3, we perform the DRO-based multi-period ED

for both transmission and distribution systems independently using fixed power exchange obtained by results in Case 2.

Table II tabulates the results of the three cases regarding the economic performance of using different coordination strategies. We use the finalized locational marginal prices in the boundary node from the transmission side upon convergence to calculate the power trade revenue, which means the downstream operator could benefit from exporting power to the upstream operator and *vice versa*. We also record the average power mismatch as the active power difference in the boundary node upon convergence.

As we compare Case 3 with Case 1 and Case 2, it is




Fig. 3. Energy hub unit dispatch for Case 1.




Fig. 4. Energy hub unit dispatch for Case 2.

straightforward to find the disconnected T&D operation is far less cost-effective than the T&D coordination. The renewable curtailment also raises if the two agents perform individual optimization because the excess power from uncertain outputs in different regions could not support each other. If we compare Case 1 with Case 2, considering the multi-energy hub in the T&D coordination yields higher profits since the explicit network modeling reduces the potentially inaccurate cost estimation of other energy sectors. Moreover, taking






Fig. 5. Comparison between different uncertainty models

TABLE III

MAXIMUM SOCP GAP VALUES OF THE POWER AND GAS NETWORKS (P.U.)

	Power Network	Gas Network
SOCP gap	0.0039	0.0062

GESSs into account contributes to better scheduling of the gas units. For the network loss, the reason why *Case 1* outperforms other cases lies in the higher capacity factor of gas units and lower power imports from the transmission system. They both reduce the total electrical distance from power sources to load buses in the distribution network.

Fig. 3 and Fig. 4 depict the detailed dispatch results for *Case 1* and *Case 2*. The gas units' dispatch is highly sensitive to the gas retail price. For example, at Hour 3-8, the gas price is the lowest in one day, making the gas units receive sufficient fuels and generate more power to charge the PESS while exporting power to the transmission grid. At noon, the PV generation increases and helps the ESS store more energy to feed the peak load at night. By comparing *Case 1* and *Case 2*, the lack of explicit gas network modeling lowers the capability of the gas generation because no GESS would help with the gas arbitrage. Moreover, the gas units could not sufficiently capture the price fluctuation without the compressor model. Hence, the weak gas units' generation capability forces the downstream operator to reduce the power export and reap lower revenues. As the CHP is the only heat source in the heat network, it needs to maintain the power level to ensure sufficient heat supplies, which is common in residential districts [36].

### B. Comparison between Uncertainty Models

To further demonstrate the advantage of using the DRO-based uncertainty model, we test cases with other uncertainty models, including *Case 4* (deterministic), *Case 5* (SP), and *Case 6* (RO). For *Case 4*, we use the K-means centroid value of historical observations to represent the uncertainty. For *Case 5*, we apply the Monte-Carlo sampling to generate 20 equiprobable scenarios and reduce (10) to a single-stage stochastic conic program. For *Case 6*, we replace the ambi-




Fig. 6. Convergence of different types of algorithms

guity set with the polyhedral uncertainty set, [34] which is constructed using the maximum and minimum values of the renewable forecast, *i.e.*,

$$\mathcal{U}^{\text{RO}} = \{\tilde{P}_{r,h} | P_{r,h}^{\min} \leq \tilde{P}_{r,h} \leq P_{r,h}^{\max}\}$$

Fig. 5 illustrates the comparison. *Case 4* serves as the base case since the problem is solved with a widely applied but inaccurate characterization of uncertainties. We could find the SP in *Case 5* yields the most cost-effective result among the three uncertainty models, which is also closest to the base case, but with more iterations required for the AAL convergence. In each AAL iteration, the Lagrangian multiplier is updated as an expected value of all scenarios' outcomes, which hinders the optimal search. RO in *Case 6* achieves the fastest convergence rate but with highly conservative solutions, as it always draws the worst-case scenario in which the renewable generation is limited. The DRO-based model in *Case 1*, comparatively, becomes the most competitive choice as it balances the trade-off between computational speed and solution conservatism. Albeit solving subproblems with different models requires different times, the AAL algorithm parallelizes the subproblem solution procedures, making the iteration counter comparable.

### C. SOCP Exactness Evaluation

Our work adopts the SOCP relaxation in both the power distribution and gas distribution systems as the branch flow model and the relaxed Weymouth equation. Note that the SOCP-based branch flow model has enjoyed wide recognition for its exactness in representing the actual AC power flow [40]. Similarly, the Weymouth equation can also be exactly relaxed via the conic formulation, as reported in [41]. To further validate the exactness of the SOCP approximation, Table III shows the maximum SOCP gaps for both the power and gas distribution networks.

As shown in Table III, the SOCP gap values are sufficiently small for both networks, which proves the proposed methods' exactness for approximating the DRO model's energy flows. It is also worth mentioning that this approximation cannot completely substitute actual energy flow analyses but could

serve as a satisfactory starting setpoint when running energy flow calculations with improved computational speed.

#### D. Decentralization Convergence Analysis

Though the AAL algorithm converges very quickly, its convergence pattern is slightly different from other centralized or decentralized methods. We are interested in investigating the AAL convergence by comparing it with a centralized method, Benders decomposition (BD), and another decentralized method, ADMM. To simplify the BD, we reduce the DRO-based subproblem to the deterministic equivalent form, and hence (12) becomes a typical two-stage SP problem. Fig. 6 reports the evolution of one boundary power injection variable when  $h = 5$  under the three algorithms. We could observe that AAL crosses the optimal solution several times because it utilizes two primal and Lagrangian updates in each iteration to facilitate the solution, which asks for more penalizing measures. While ADMM also has this pattern, its convergence is slower than AAL. The centralized approach of BD never crosses the optimal solution since the bounding cuts are optimally conditioned, which guarantees the global optimality albeit a low convergence rate.

#### E. Scalability Test

In this subsection, we provide an additional test on a large-scale system to further validate the scalability of the proposed method. The test system is a T118E20 system consisting of one IEEE 118-bus system with high renewable penetration [42] and 20 duplicates of the multi-energy hub from Fig. 2. We place the 20 energy hubs in the original load buses and keep the renewable generators with the same dataset in Section IV to generate the ambiguity set.

Fig. 7 presents the performance of the proposed method in the large-scale test case. Since the proposed method is a distributed algorithm, parallel computing is a natural way to maximize resource usage for solving the problem. Each transmission and distribution operator can solve their scheduling problem locally and then communicate the Lagrangian information. Hence, we record the highest computational time per iteration that one agent needs to take to solve the local problem. We also report the objective value deviation from the optimally converged result to demonstrate the convergence progress. From Fig. 7, we observe that by leveraging parallel computing, solving large-scale T&D scheduling problems is efficient at the minute level due to the fast convergence rate of the AAL method.

#### V. CONCLUDING REMARKS

This paper proposes a novel scheduling framework as a market paradigm for the T&D coordinative operation. The proliferating penetration of renewable generation and the increasingly closer connection with other energy sectors create more uncertainties to the distribution side, propagating system-level power mismatch to the transmission side and leading to suboptimal decision-making. We consider the multi-energy hub in the distribution system to fill this gap with state-of-the-art modeling of uncertainties in both upstream and downstream




Fig. 7. Computational performance of the scalability test

operators. Furthermore, the nature of T&D coordination requires privacy-preserving operations between multiple agents, while the AAL-based workflow shows its efficacy for handling such a problem. The numerical experiments confirm the effectiveness of the proposed modeling and solution strategies.

Future studies include considering a more realistic and comprehensive market structure, such as the UC and balancing market in the decentralized T&D scheme. It is also interesting to further investigate whether the multi-energy hub as a distribution system could help the transmission operator mitigate network congestions and contribute to carbon neutrality.

#### REFERENCES


- [1] "Coordination of Transmission and Distribution Operations in High Distributed Energy Resource Electric Grid," Tech. Rep. 17-IEPR-12, CAISO, June 2017.
- [2] Federal Energy Regulatory Commission, "Participation of Distributed Energy Resource Aggregations in Markets Operated by Regional Transmission Organizations and Independent System Operators," Sept. 2020. FERC Order 2222.
- [3] S. Yin, J. Wang, Z. Li, and X. Fang, "State-of-the-art Short-term Electricity Market Operation with Solar Generation: A Review," *Renewable and Sustainable Energy Reviews*, vol. 138, p. 110647, 2021.
- [4] "Distribution System Operator (DSO) Models for Utility Stakeholders," tech. rep., Black & Veatch Management Consulting, Jan. 2021.
- [5] S. Yin, J. Wang, and H. Gangammanavar, "Stochastic Market Operation for Coordinated Transmission and Distribution Systems," *IEEE Transactions on Sustainable Energy*, vol. 12, no. 4, pp. 1996–2007, 2021.
- [6] A. Kargarian, J. Mohammadi, J. Guo, S. Chakrabarti, M. Barati, G. Hug, S. Kar, and R. Baldick, "Toward Distributed/Decentralized DC Optimal Power Flow Implementation in Future Electric Power Systems," *IEEE Transactions on Smart Grid*, vol. 9, no. 4, pp. 2574–2594, 2018.
- [7] D. Xu, Q. Wu, B. Zhou, C. Li, L. Bai, and S. Huang, "Distributed Multi-Energy Operation of Coupled Electricity, Heating, and Natural Gas Networks," *IEEE Transactions on Sustainable Energy*, vol. 11, no. 4, pp. 2457–2469, 2020.
- [8] Z. Li, Q. Guo, H. Sun, and J. Wang, "A New LMP-Sensitivity-Based Heterogeneous Decomposition for Transmission and Distribution Coordinated Economic Dispatch," *IEEE Transactions on Smart Grid*, vol. 9, no. 2, pp. 931–941, 2018.
- [9] Z. Chen, Z. Li, C. Guo, J. Wang, and Y. Ding, "Fully Distributed Robust Reserve Scheduling for Coupled Transmission and Distribution Systems," *IEEE Transactions on Power Systems*, vol. 36, no. 1, pp. 169–182, 2021.
- [10] P. Li, Q. Wu, M. Yang, Z. Li, and N. D. Hatzigiorgiou, "Distributed Distributionally Robust Dispatch for Integrated Transmission-Distribution Systems," *IEEE Transactions on Power Systems*, vol. 36, no. 2, pp. 1193–1205, 2021.

- [11] A. Rabiee, A. Keane, and A. Soroudi, "Enhanced Transmission and Distribution Network Coordination to Host More Electric Vehicles and PV," *IEEE Systems Journal*, pp. 1–12, 2021.
- [12] M. A. Bragin and Y. Dvorkin, "TSO-DSO Operational Planning Coordination Through " $l_1$ -Proximal" Surrogate Lagrangian Relaxation," *IEEE Transactions on Power Systems*, vol. 37, no. 2, pp. 1274–1285, 2022.
- [13] M. K. Arpanahi, M. E. H. Golshan, and P. Siano, "A Comprehensive and Efficient Decentralized Framework for Coordinated Multiperiod Economic Dispatch of Transmission and Distribution Systems," *IEEE Systems Journal*, vol. 15, no. 2, pp. 2583–2594, 2021.
- [14] J. Hu, X. Liu, M. Shahidehpour, and S. Xia, "Optimal Operation of Energy Hubs With Large-Scale Distributed Energy Resources for Distribution Network Congestion Management," *IEEE Transactions on Sustainable Energy*, vol. 12, no. 3, pp. 1755–1765, 2021.
- [15] C. Shao, Y. Ding, P. Siano, and Y. Song, "Optimal Scheduling of the Integrated Electricity and Natural Gas Systems Considering the Integrated Demand Response of Energy Hubs," *IEEE Systems Journal*, vol. 15, no. 3, pp. 4545–4553, 2021.
- [16] W. Huang, X. Zhang, K. Li, N. Zhang, G. Strbac, and C. Kang, "Resilience Oriented Planning of Urban Multi-Energy Systems With Generalized Energy Storage Sources," *IEEE Transactions on Power Systems*, pp. 1–1, 2021.
- [17] Y. Li, Z. Li, F. Wen, and M. Shahidehpour, "Privacy-Preserving Optimal Dispatch for an Integrated Power Distribution and Natural Gas System in Networked Energy Hubs," *IEEE Transactions on Sustainable Energy*, vol. 10, no. 4, pp. 2028–2038, 2019.
- [18] P. Zhao, Z. Cao, D. D. Zeng, C. Gu, Z. Wang, Y. Xiang, M. Qadrdan, X. Chen, X. Yan, and S. Li, "Cyber-resilient multi-energy management for complex systems," *IEEE Transactions on Industrial Informatics*, vol. 18, no. 3, pp. 2144–2159, 2022.
- [19] Z. Yang, J. Hu, X. Ai, J. Wu, and G. Yang, "Transactive Energy Supported Economic Operation for Multi-Energy Complementary Microgrids," *IEEE Transactions on Smart Grid*, vol. 12, no. 1, pp. 4–17, 2021.
- [20] Z. Li, Q. Guo, H. Sun, and J. Wang, "Coordinated Economic Dispatch of Coupled Transmission and Distribution Systems Using Heterogeneous Decomposition," *IEEE Transactions on Power Systems*, vol. 31, no. 6, pp. 4817–4830, 2016.
- [21] Z. Li, H. Sun, Q. Guo, J. Wang, and G. Liu, "Generalized Master-Slave-Splitting Method and Application to Transmission-Distribution Coordinated Energy Management," *IEEE Transactions on Power Systems*, vol. 34, no. 6, pp. 5169–5183, 2019.
- [22] C. He, X. Zhang, T. Liu, and L. Wu, "Distributionally Robust Scheduling of Integrated Gas-Electricity Systems With Demand Response," *IEEE Transactions on Power Systems*, vol. 34, no. 5, pp. 3791–3803, 2019.
- [23] M. Daneshvar, B. Mohammadi-Ivatloo, M. Abapour, S. Asadi, and R. Khanjani, "Distributionally Robust Chance-Constrained Transactive Energy Framework for Coupled Electrical and Gas Microgrids," *IEEE Transactions on Industrial Electronics*, vol. 68, no. 1, pp. 347–357, 2021.
- [24] N. Chatzipanagiotis and M. M. Zavlanos, "On the Convergence of a Distributed Augmented Lagrangian Method for Nonconvex Optimization," *IEEE Transactions on Automatic Control*, vol. 62, no. 9, pp. 4405–4420, 2017.
- [25] J. A. Ansere, G. Han, L. Liu, Y. Peng, and M. Kamal, "Optimal Resource Allocation in Energy-Efficient Internet-of-Things Networks With Imperfect CSI," *IEEE Internet of Things Journal*, vol. 7, no. 6, pp. 5401–5411, 2020.
- [26] B. Zeng and L. Zhao, "Solving Two-stage Robust Optimization Problems Using a Column-and-Constraint Generation Method," *Oper. Res. Lett.*, vol. 41, pp. 457–461, 2013.
- [27] "Business Practices Manual: Energy and Operating Reserve Markets - Attachment B: Day-Ahead Energy and Operating Reserve Market Software Formulations and Business Logic," Tech. Rep. BPM-002-r21, MISO, Oct. 2021.
- [28] Y. He, M. Shahidehpour, Z. Li, C. Guo, and B. Zhu, "Robust Constrained Operation of Integrated Electricity-Natural Gas System Considering Distributed Natural Gas Storage," *IEEE Transactions on Sustainable Energy*, vol. 9, no. 3, pp. 1061–1071, 2018.
- [29] Y. Cao, W. Wei, L. Wu, S. Mei, M. Shahidehpour, and Z. Li, "Decentralized Operation of Interdependent Power Distribution Network and District Heating Network: A Market-Driven Approach," *IEEE Transactions on Smart Grid*, vol. 10, no. 5, pp. 5374–5385, 2019.
- [30] Y. Lin, X. Zhang, S. Yin, J. Wang, and D. Shi, "Real-Time Economic Dispatch for Integrated Energy Microgrid Considering Ancillary Services," in *2020 IEEE Power Energy Society General Meeting (PESGM)*, pp. 1–5, 2020.
- [31] L. Han, T. Morstyn, and M. McCulloch, "Incentivizing prosumer coalitions with energy management using cooperative game theory," *IEEE Transactions on Power Systems*, vol. 34, no. 1, pp. 303–313, 2019.
- [32] C. Duan, W. Fang, L. Jiang, L. Yao, and J. Liu, "Distributionally Robust Chance-Constrained Approximate AC-OPF With Wasserstein Metric," *IEEE Transactions on Power Systems*, vol. 33, no. 5, pp. 4924–4936, 2018.
- [33] Y. Zhou, Z. Wei, M. Shahidehpour, and S. Chen, "Distributionally Robust Resilient Operation of Integrated Energy Systems Using Moment and Wasserstein Metric for Contingencies," *IEEE Transactions on Power Systems*, vol. 36, no. 4, pp. 3574–3584, 2021.
- [34] S. Yin and J. Wang, "Generation and Transmission Expansion Planning Towards a 100% Renewable Future," *IEEE Transactions on Power Systems*, pp. 1–1, 2020.
- [35] C. Wang, W. Wei, J. Wang, L. Bai, and Y. Liang, "Distributed Optimal Gas-Power Flow Using Convex Optimization and ADMM," *arXiv: Optimization and Control*, 2016.
- [36] B. Liu, K. Meng, Z. Y. Dong, and W. Wei, "Optimal Dispatch of Coupled Electricity and Heat System With Independent Thermal Energy Storage," *IEEE Transactions on Power Systems*, vol. 34, no. 4, pp. 3250–3263, 2019.
- [37] A. Kargarian and Y. Fu, "System of Systems Based Security-Constrained Unit Commitment Incorporating Active Distribution Grids," *IEEE Transactions on Power Systems*, vol. 29, no. 5, pp. 2489–2498, 2014.
- [38] CANWEA, "https://canwea.ca/wind-integration-study/wind-data/."
- [39] NREL, "https://www.nrel.gov/grid/solar-power-data.html."
- [40] M. Farivar and S. H. Low, "Branch Flow Model: Relaxations and Convexification: Part i," *IEEE Trans. on Power Systems*, vol. 28, pp. 2554–2564, Aug 2013.
- [41] C. Wang, W. Wei, J. Wang, L. Bai, Y. Liang, and T. Bi, "Convex optimization based distributed optimal gas-power flow calculation," *IEEE Transactions on Sustainable Energy*, vol. 9, no. 3, pp. 1145–1156, 2018.
- [42] I. Peña, C. B. Martinez-Anido, and B.-M. Hodge, "An Extended IEEE 118-Bus Test System With High Renewable Penetration," *IEEE Transactions on Power Systems*, vol. 33, no. 1, pp. 281–289, 2018.



**Shengfei Yin** (M'16) Dr. Shengfei Yin is a Senior Optimization Engineer at Ascend Analytics, LLC. He is the maintainer and current major model developer of the company's most profit-earning software for energy market simulation, PowerSIMM. In the past, he was a Postdoctoral Research Associate with the Electricity Markets and Policy Department at Lawrence Berkeley National Laboratory. He also held positions of R&D Fellow at Midcontinent Independent System Operator and Research Engineer Intern at National Renewable Energy Laboratory.

He received the B.Eng. degree from Hunan University, PRC, in 2016, the M.S. degree from Illinois Institute of Technology, USA, in 2017, and the Ph.D. degree from Southern Methodist University, USA, in 2021, all in Electrical Engineering with electricity market specialization. He finished the Ph.D. degree with the university's Outstanding Graduate Award. His research interests include operations research and artificial intelligence with applications in electricity market design and operations. He serves as a reviewer for *IEEE Transactions on Smart Grid* and *IEEE Transactions on Power Systems*, etc.



**Jianhui Wang** (M'07-SM'12-F'20) Dr. Jianhui Wang is a Professor with the Department of Electrical and Computer Engineering at Southern Methodist University. His research interests include smart grid, microgrids, power system operation and control, renewable integration, grid resilience and cybersecurity.

Dr. Wang is the past Editor-in-Chief of *IEEE Transactions on Smart Grid* and an IEEE PES Distinguished Lecturer. He is also a guest editor of a *Proceedings of the IEEE* special issue on power grid

resilience. He is the recipient of the IEEE PES Power System Operation Committee Prize Paper Award in 2015, the 2018 Premium Award for Best Paper in *IET Cyber-Physical Systems: Theory & Applications*, the Best Paper Award in *IEEE Transactions on Power Systems* in 2020, and the IEEE PES Power System Operation, Planning and Economics Committee Prize Paper Award in 2021. Dr. Wang is a Clarivate Analytics highly cited researcher for production of multiple highly cited papers that rank in the top 1% by citations for field and year in Web of Science (2018-2021). He is a Fellow of IEEE.